



CERTALARM -
the Quality Mark
for Fire
& Security

CERTIFICATE

No 000076 / 01

In accordance with the **CERTALARM** Rules
and Certification System 5, as defined in ISO / IEC Guide 67,
we certify that the product

WS4904(P) / WS8904(P) - Wireless PIR 433/868 MHz

is in conformity with the following standard(s)

EN50131-2-2:2008

Passive infrared detectors

EN50131-5-3:2005+A1:2008

Interconnections equipment using radio frequency techniques

EN50131-6:2008

Power Supply Equipment

Digital Security Controls (DSC) a division of Tyco Safety Products

3301 Langstaff Road, L4K 4L2 Concord, Ontario, CANADA

is authorised to use the **CERTALARM** Mark on the above mentioned product

This certificate is valid until:

6th November 2016

Signed on behalf of Intertek Testing & Certification Ltd.

6th November 2012



010
Accredited to EN 45011:1998

Daniel Griffin
Business Stream Manager



Intertek Testing and Certification Ltd, Intertek House, Cleeve Road, Leatherhead, Surrey, England. KT22 7SB.
Tel: +44 (0) 1372 370900 Fax: +44 (0)1372 370943 Email: certificates@intertek.com Web: www.intertek.com

www.certalarm.org

This certificate and the annex(es) may only be copied completely and without any additions.

CERTIFICATE

No 000076 / 01 - Annex No 1

Takes into account for the following product:

WS4904(P)/WS8904(P) ? wireless PIR 433/868 MHz

The optional features of the specifications that are included in the product and test report:

The WS4904 and WS8904 are identical to the WS4904P/WS8904P except for the applied lenses where WS4904P/WS8904P use a pet immune lens

Certified with standard lens BV-L1-UV and not optional lenses

Equipment security grade : 2

Equipment environmental class : II

Equipment class : Fixed

Power Supply: Type C

The radio part has been tested previously in a similar configuration on the RFK5500-433 and RFK5500-868 Keypad with hardware version UA510 Rev .09 and software revision 1.02

Test Report Number:

RFK5500-433 EN50131-5-3 Telef Rpt 99831980-rev1

WS4904(P) EN50130-5 ANPI Test Report BIS-ETP-0004

WS4904P EN50131-2-2 Telef report 20113805800 rev1

WS4904P EN50131-2-2 TRTelefication 20113805800

WS4904P_WS4904 Telefication Cert 11229059_AA01

Remarks and observations

Validity of Certificate;

The Certificate remains valid based upon satisfactory annual factory production control audits and follow up re-testing every 2 years from Certificate issue

CERTIFICATE

No 000076 / 01 - Annex No 2

Documents submitted

75000029 General Assembly drawing ? Issue A/1
WS4904P (UA523_REV02)_SCH ? Issue 02
WS4904P (UA523 Rev 02) Parts List ? Issue 02 (005)
WS4904P (UA523_Rev02)_pcb ? Issue 02
WS4904P (UA523_Rev02)_pcb. page 1- Issue 02
WS4904P (UA523_Rev02)_pcb.pdf page 4 ? Issue 02
Backplate 08001354 ? Issue B/2
Base 08006840 ? Issue B/1
Cover 08006839 ? Issue A/2
WS4904(P) Label 18007983R003 ? Issue n/a
WS4904P Installation Manual 29007298R001 ? Issue n/a

DISCLAIMER

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of the CertAlarm Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect